

Product

Rubber pipe insulation "Insul Tube".

Manufacturer

N.M.C. S.a.
Address: Rovert 10, B-4731 Raeren (Eynatten), BELGIUM.

Supplier

NMC Termonova OY
Address: Torppanummentie 44, 10210 Inkoo, FINLAND.

Product description

Thickness of product: 6-50 mm;
Density: 45-100 kg/m³.

Classification standard

EN 13501-1:2007+A1:2009 "Fire classification of construction products and building elements. Part 1: Classification using test data from reaction to fire tests".

Classification

Based on test results (EN 13823 and EN ISO 11925-2) rubber pipe insulation "Insul Tube" meets the reaction to fire class:

B-s3, d0.

Basis

Decision of the Board No 2-1/11-45.

Certificate validity conditions

This certificate is issued on 27.04.2007, changed 24.08.2011 and remains valid until 27.04.2012 as long as the manufacturing conditions in the factory are not modified significantly and FPC has been made in time. The validity of the certificate can be checked on the Internet at www.inspecta.ee.



Olavi Üits
Responsible person